



IN REPLY REFER TO:

MT-450

United States Department of the Interior

BUREAU OF RECLAMATION

Great Plains Region

Montana Area Office

P.O. Box 30137

Billings, Montana 59107-0137



December 26, 2013

FAXOGRAM: Water Order Change

To: Chief, Power Supply and Billing Division, WAPA, Watertown, South Dakota
Attention: F-6300
Chief, Power Dispatching Branch, WAPA, Loveland, Colorado
Attention: J-4120
Facilities Manager, Helena, Montana
Attention: MT-800, MT-810, MT-831
Project Manager, Mills, Wyoming
Attention: WY-4000, WY-4100, WY-6400
PPL Energy Plus, LLC, Butte, Montana
Attention: Resource Coordinator, Deb Mallowney

From: Reservoir and River Operations, Billings, Montana /S/ Stephanie Micek

Subject: **Canyon Ferry Water Release Order - CFR No. 14-07**

CURRENT RESERVOIR CONDITIONS:

Elevation: 3783.71 Storage: 1,467,575 acre-feet; River Release: 2,900 cfs; Inflow: 3,200 cfs;

GENERAL COMMENTS:

An outage on Unit #1 will occur January 6th through February 6th for triennial maintenance. During this time the turbine releases will be restricted and limited to a 2-unit capacity. In response, the following operation change is required at Canyon Ferry Dam and Powerplant.

CANYON FERRY RELEASES AND OPERATIONS: All times are Mountain Standard Time (MST)

At 1300 hour on Monday, January 6, 2014 through 1600 hour on Thursday, February 6, 2014:

Maintain releases through the river outlet gates at 0 cfs.

Maintain releases through the spillway gates at 0 cfs.

Maintain turbine release at \approx 2,900 cfs (\approx 686 MW-Hrs/day using 101.5 cfs/mw).

Maintain release for Helena Valley Project at 0 cfs.

Maintain release to the Missouri River at 2,900 cfs.

Maintain total release from Canyon Ferry at 2,900 cfs.